

M

INVOICE No.

IN ACCOUNT WITH

C. T. & W. P. STOVER

GENERAL CONTRACTORS

116 ALEXANDER AVENUE

MAIL ADDRESS: P. O. BOX 87, CLAREMONT

PHONE: CLAREMONT 6261

TERMS: NET CASH

ORDERED BY

June 22, 1942

REPORT ON TANK TESTS
EAGLE FIELD, Dos Palos, California

Capacity: 10,000 gallons

Built of: Concrete - using Trip-L-Seal

Purpose: Fuel Oil Storage

Test on Gasoline - (Douglas Aviation)

| Wednesday 17th | Temp. top tank | Temp. Gas | Stick Depth |
|----------------|----------------|-----------|-------------|
| 10 AM | 111° | 72° | 40 1/2" |
| 12 Noon | 114° | 72° | 40 1/2" |
| 2 PM | 116° | 72° | 40 1/2" |
| 4 PM | 117° | 72° | 40 1/2" |
| Thursday 18th | | | |
| 10 AM | 110° | 72° | 40 1/2" |
| 12 Noon | 114° | 72° | 40 1/2" |
| 2 PM | 119° | 72.1° | 40 1/2" |

Test on Deisel Fuel Oil - (Standard Oil Co.)

| | | | | |
|---------------|------|------|-----|---------|
| Friday 19th | 4:30 | 116° | 84° | 46 1/2" |
| Saturday 20th | 9:30 | 92° | 80° | 46 1/2" |
| Sunday 21st | 3:30 | 114° | 80° | 46 1/2" |
| Monday 22nd | 9:30 | 100° | 80° | 46 1/2" |

The above test made at EAGLE FIELD, Dos Palos, California
and checked by

J. C. Stover
Superintendent for
C. T. & W. P. Stover

TANK: Diameter 17 feet
Depth 8 feet
Walls 7 inches